

Received: 15 July 2016 Accepted: 17 February 2017 Published online: 23 March 2017

# **OPEN** Multimode fiber tip Fabry-Perot cavity for highly sensitive pressure measurement

W. P. Chen, D. N. Wang, Ben Xu, C. L. Zhao & H. F. Chen

We demonstrate an optical Fabry-Perot interferometer fiber tip sensor based on an etched end of multimode fiber filled with ultraviolet adhesive. The fiber device is miniature (with diameter of less than 60 µm), robust and low cost, in a convenient reflection mode of operation, and has a very high gas pressure sensitivity of -40.94 nm/MPa, a large temperature sensitivity of 213 pm/ $^{\circ}$ C within the range from 55 to 85 °C, and a relatively low temperature cross-sensitivity of 5.2 kPa/°C. This device has a high potential in monitoring environment of high pressure.

Optical fiber Fabry-Perot (FP) interferometric pressure sensors have been attractive for a wide range of applications in biomedicine, healthcare, civil engineering, and automotive and aerospace industries<sup>1</sup>. Especially the FP cavity at the fiber tip can provide a convenient reflection mode of operation.

There are two types of optical fiber FP interferometer (FPI) pressure sensors, operated on cavity length change<sup>2-9</sup> or dominated by cavity refractive index (RI) variation<sup>10–14</sup>, respectively. Many FPI sensors operated on cavity length change have relatively low pressure sensitivity except those based on thin diaphragm<sup>2–5</sup>. One of the key elements to determine the pressure sensitivity of the FPI is the thickness of the diaphragm employed. A thin diagram has a relatively high sensitivity. However, the mechanical strength of a thin diagram is rather poor as the thin diaphragm attached at the fiber end is fragile and easily to be cracked. Moreover, the FPI sensors based on a thin diagram exhibit a small measurement range, typically in a few tens of kPa<sup>4,5</sup>. Several FPI configurations operated on cavity RI variation have been developed for gas pressure sensing. For instance, an FPI tip based on side-hole dual-core photonic crystal fiber (PCF) exhibits a measurement range from 0 to 500 MPa and a sensitivity of 32 pm/MPa<sup>12</sup>. Other FPI tip sensors based on twin-core PCF or fiber Bragg grating (FBG) also have similar performance<sup>13, 14</sup>. Although the FPI sensors operated on cavity RI variation usually have a large measurement range and good robustness, their pressure sensitivities are relatively low, typically in a few tens of pm/MPa<sup>11-14</sup>, unless a carefully designed sensor head is utilized15, which increases the device complexity and the fabrication

Another key element that determines the pressure sensitivity of the FPI operated on cavity length change is the size of the diaphragm employed 16, and the larger the size, the higher the sensitivity that can be achieved. In general, the size of diagram is limited by the diameter of the fiber core of single mode fiber (SMF), which is less than 9 µm. By contrast, the core size of multimode fiber (MMF) is more than 60 µm. Moreover, more sensitivity enhancement would be expected if the diaphragm could utilize the whole diameter of MMF.


Here we propose and experimentally demonstrate a new type of optical fiber tip FPI pressure sensor based on an etched end of MMF filled with ultraviolet (UV) adhesive. Because of the large size of tapered hole formed in the MMF and the large elasticity coefficient of UV adhesive, the fiber tip FP cavity is compact in size, robust in structure, simple in fabrication, and convenient in operation. The gas pressure sensitivity achieved within the measurement range between 0 and 1 MPa (limited by the pressure meter we used) is -40.94 nm/MPa. The temperature sensitivity of the device is 213 pm/°C, within the range from 55 to 85 °C, which gives a relatively low temperature cross-sensitivity of 5.2 kPa/°C. Moreover, the device can also be used for RI sensing with a sensitivity of ~-73.54 nm/RIU (RI unit) within the range from 1.332 to 1.372, which shows its versatile measurement capability.

# **Device Fabrication and Principle**

The optical fiber FP cavity sensor head is composed of an etched MMF filled with UV adhesive. During the sensor head fabrication process, the end face of MMF with a core diameter of  $62.5\,\mu m$  and a nominal effective RI of

College of Optical and Electronic Technology, China Jiliang University, Hangzhou, China. Correspondence and requests for materials should be addressed to D.N.W. (email: eednwang@cjlu.edu.cn)

**Figure 1.** Schematic diagram of the fabrication process of the optical fiber sensor head. (a) A taper-shaped hole at the end of MMF is formed by HF etching. (b) The taper-shaped hole at the end of MMF is filled with UV adhesive to form an inner air-cavity. (c) The UV adhesive is solidified.



**Figure 2.** (a) Schematic diagram and (b) the microscope image of the sensor head.

1.4682 (at 1550 nm) is etched by use of hydrofluoric (HF) acid to form a tapered hole cavity. The UV adhesive (Norland, NOA68) employed can sustain the temperature change from  $-80\,^{\circ}$ C to  $90\,^{\circ}$ C, and has the RI of 1.54 (at 1550 nm). The fabrication process of the device is illustrated in Fig. 1.

Initially, a section of MMF with length of  $\sim$ 20 cm is immersed into HF acid with the concentration of 40% and the immersed length is  $\sim$ 0.25 cm as shown in Fig. 1(a). The etching process takes  $\sim$ 10 minutes before a taper-shaped hole of several tens micrometers in depth is formed at the end face of the MMF. Next, the taper-shaped hole is filled with UV adhesive by use of following steps as illustrated in Fig. 1(b):

- 1. UV adhesive attached on the tip of a tapered optical fiber is filled into the taper-shaped hole.
- 2. UV adhesive attached on the flat end of an MMF is used to seal the taper-shaped hole and form an inner air-cavity due to the remaining air in the taper-shaped hole region.
- 3. The shape and position of the inner air-cavity can be controlled by using a tapered fiber tip to push the UV adhesive at appropriate position, while observing the reflection spectra of the device via an optical spectrum analyzer (OSA).

Finally, the UV adhesive is solidified by use of a UV light as shown in Fig. 1(c), to provide a robust structure of the device.

The size of inner air-cavity can also be controlled by adjusting the usage of UV adhesive used. For instance, if a small inner air-cavity is needed, less UV adhesive should be used.

The schematic diagram and the microscope image of the sensor head are shown in Fig. 2. There are three main reflection surfaces in the device sensor head, at the interfaces of adhesive-air  $(R_1)$ , air-adhesive  $(R_2)$  and adhesive-air  $(R_3)$ , respectively, which form three FP cavities.

The two reflection surfaces of  $R_1$  and  $R_2$  create an FP cavity  $(C_1)$ . When light beam traveling along the MMF arrives at  $R_1$ , part of the light is reflected back, and the rest continues to propagate until reaching  $R_2$  and experiencing partial reflection. The light beam transmitted through  $R_2$  finally arrives at  $R_3$  and is partially reflected again. The two reflection surfaces of  $R_2$  and  $R_3$  thus forming another FP cavity  $(C_2)$ . Meanwhile, the two reflection surfaces  $R_1$  and  $R_3$  can also form an FP cavity  $(C_3)$  with a cavity length that is equal to the sum of cavity lengths of  $C_1$  and  $C_2$ .

The reflection spectrum of the device sample fabricated and its corresponding spatial frequency spectrum obtained by use of fast Fourier transform are displayed in Fig. 3. It can be observed from the figure that there are two dominant side peaks in the spatial frequency spectrum, located at  $\sim 0.0239$  and  $\sim 0.0563$  nm<sup>-1</sup>, respectively, which indicates an interference pattern of two FP cavities.

The well-known expression of free spectral range (FSR) is written as

$$FSR = \lambda^2 / 2nL \tag{1}$$




Figure 3. (a) Reflection spectra of the device sample. (b) Spatial frequency spectra of the device sample.




Figure 4. Reflection spectra of the FP cavity device obtained from theoretical simulations and experiment.

where  $\lambda$  is the wavelength, n is the RI of the cavity, and L is the cavity length. As the RI of UV adhesive is 1.54 and the cavity lengths of  $C_1$  and  $C_2$  are ~37.7  $\mu$ m, ~18.7  $\mu$ m, respectively, the cavity length of  $C_3$  is the sum of the length of  $C_1$  and  $C_2$ , i.e., 56.4  $\mu$ m. By taking the wavelength of 1550 nm, the spatial frequency peak positions for three FP cavities  $C_1$ ,  $C_2$  and  $C_3$  can be determined as ~0.0314, ~0.0239 and ~0.0554 nm<sup>-1</sup>, respectively. This reveals that  $C_2$  and  $C_3$  are the dominant FP cavities as the experimentally obtained results agree well with those obtained from the calculations. Thus, the output spectrum of the device consists of two superimposed FP spectra of  $C_2$  and  $C_3$ .

The output light intensity (I) of FP cavity  $C_2$  and  $C_3$  can be written as

$$I = I_1 + I_2 + 2I_3 + 2\sqrt{I_2I_3}\cos\Phi_{23} + 2\sqrt{I_1I_3}\cos\Phi_{13}$$
 (2)

where  $I_1$ ,  $I_2$ , and  $I_3$  are the light intensity reflected from adhesive-air surface  $R_1$ , air-adhesive surface  $R_2$ , and adhesive-air surface  $R_3$ , respectively, and  $\Phi_{23}$  and  $\Phi_{13}$  are the introduced phase shifts of the cavity  $C_2$  and  $C_3$ , respectively, given by

$$\Phi_{23} = \frac{4\pi n_2 L_2}{\lambda} \tag{3}$$

$$\Phi_{13} = \frac{4\pi (n_1 L_1 + n_2 L_2)}{\lambda} \tag{4}$$

where  $n_1$  and  $n_2$  are the RI of air, UV adhesive,  $L_1$  and  $L_2$  are cavity length of  $C_1$  and  $C_2$ , respectively.

From Eqns (2)–(4), by taking  $n_1 = 1$ ,  $n_2 = 1.54$ , and the reflection coefficient of the surface of  $R_1$ ,  $R_2$  and  $R_3$  as  $(n_1 - n_2)^2/(n_1 + n_2)^2 = 0.0452$ , the reflection spectrum of the FP cavity device can be simulated and the result obtained is displayed in Fig. 4, together with that obtained from the experiment as shown previously in Fig. 3(a), to facilitate the comparison. It can be seen from Fig. 4 that the two reflection spectra have nearly the same waveform, and their intensity difference comes from the insertion loss of the device while the wavelength shift existed





Figure 5. Schematic diagram of experimental setup.



**Figure 6.** Dip wavelength shift with the increase of pressure, and the inset shows the reflection spectra of the device at different pressures.

in the experimental fringe pattern is likely due to the initial phase of the fringe pattern and the dispersion effect of the optical fiber.


# **Experiments and Discussions**

The experimental setup used to test the response of FP sensor head to gas pressure is displayed in Fig. 5. Light output from a broadband light source (BBS) is introduced to the FP sensor head via a circulator. The sensor head is placed in a gas chamber, where the gas pressure can be adjusted by use of an air pump (Wisdom Billiton, Y039), measured by a pressure meter (ZHITUO, YB-150). The sensor output is directed to an optical spectrum analyzer (OSA) with the resolution of 0.05 nm to monitor the spectrum.


In the pressure measurement, the fiber in the chamber was kept in a straight line to avoid any bending-induced effects. The pressure was increased from 0.02 to 0.04 and then to 0.92 MPa with a step of 0.04 MPa, and the reflection spectrum was monitored in real-time by use of an OSA. Figure 6 and its inset demonstrate the shift of dip wavelength in the reflection spectrum with the pressure variation. It can be seen from the figure that the dip wavelength is decreased with the increase of pressure values from 0.02 to 0.92 MPa, and a good linear relationship can be obtained. The pressure sensitivity achieved is -40.94 nm/MPa.

The temperature effects on the fiber sensor device were investigated by placing the sensor head in an electrical oven and gradually increasing the temperature from room temperature to 85 °C with a step of 5 °C. The temperature was maintained for 10 min at each step to make sure the temperature in the chamber was stabilized. The dip wavelength shift with the temperature variation is demonstrated in Fig. 7, where the inset shows the reflection spectra at different temperatures. A fringe dip near ~1540 nm at the temperature of 30 °C is found to experience a red shift with the increase of temperature. The highest sensitivity obtained is ~213 pm/°C within the temperature range from 55 °C to 85 °C. However, considering of the pressure sensitivity of -40.94 nm/MPa obtained in the experiment, the temperature cross-sensitivity is calculated to be only 5.2 kPa/°C, which is much smaller than that of the sensors based on side-hole dual-core PCF<sup>12</sup> (1 MPa/°C) and on FBG in the SMF (2.3 MPa/°C)<sup>14</sup>.

The device can also be used for RI sensing. In the experiment, the device sample was immersed into a series of RI liquids and the reflection spectra recorded had a resolution of  $0.05\,\mathrm{nm}$ . Each time after the liquid sample was measured, the fiber sensor head was rinsed with water carefully until the original spectrum (i.e., the reference spectrum) could be restored and no residue liquid was left on the sensor head surface. Figure 8 shows the interference fringe dip wavelength shift with the RI change and the sensitivity of  $\sim 73.54\,\mathrm{nm/RIU}$  was achieved. In the inset of Fig. 8, the wavelength variation as a function of RI is plotted.



**Figure 7.** Fringe dip wavelength shift with the temperature variation. Inset shows the reflection spectra of the device at different temperatures.



**Figure 8.** Dip wavelength shift with RI, and the inset shows the reflection spectra of the device at different RI values.

Currently, the pressure measurement range achieved in the experiment is limited by the air pump used, which only provides a pressure value up to 1 MPa. However, our device has the potential of achieving much higher pressure measurement range due to its robust structure. As a number of wavelength dips exist in the reflection spectrum as shown in Fig. 3(a), and the device is sensitive to a range of physical parameters, a simultaneous multiple parameter measurement can be expected.

### Conclusion

To summarize, we have proposed and fabricated an optical fiber FP interferometer by use of etched MMF filled with UV adhesive. The gas pressure variation induces the air-cavity length change, which causes the change in optical path difference of the FPI, and in turn leads to the reflection spectrum shift. The sensor device exhibits a high pressure sensitivity of  $-40.94\,\text{nm/MPa}$  and a good temperature sensitivity of  $213\,\text{pm/°C}$  within the range from  $55\,^\circ\text{C}$  to  $85\,^\circ\text{C}$ , and a RI sensitivity of  $\sim -73.54\,\text{nm/RIU}$  within the range from 1.332 to 1.372. The temperature cross-sensitivity of the device is  $5.2\,\text{kPa/°C}$ . Such a device is based on low cost MMF, compact in size, robust in structure, simple in fabrication, convenient in operation, which makes it highly attractive for pressure sensing.

## References

- 1. Roriz, P. et al. Review of fiber-optic pressure sensors for biomedical and biomechanical applications. J. Biomed. Opt. 18, 050903 (2013).
- Pevec, S. & Donlagic, D. Miniature all-fiber Fabry-Perot sensor for simultaneous measurement of pressure and temperature. Appl. Opt. 51, 4536-4541 (2012).
- 3. Guo, F., Fink, T., Han, M., Koester, L., Turner, J. & Huang, J. High-sensitivity, high-frequency extrinsic Fabry–Perot interferometric fiber-tip sensor based on a thin silver diaphragm. *Opt. Lett.* 37, 1505–1507 (2012).
- 4. Xu, F. et al. High-sensitivity Fabry-Perot interferometric pressure sensor based on a nanothick silver diaphragm. Opt. Lett. 37, 133-135 (2012).
- 5. Ma, J., Jin, W., Ho, H. L. & Dai, J. Y. High-sensitivity fiber-tip pressure sensor with graphene diaphragm. *Opt. Lett.* 37, 2493–2495 (2012).
- 6. Jin, L., Guan, B. O. & Wei, H. F. Sensitivity characteristics of Fabry-Perot pressure sensors based on hollow-core microstructured fibers. *IEEE J. Lightwave Technol.* 31, 2526–2532 (2013).

- 7. Eom, J. et al. Fiber optic Fabry–Perot pressure sensor based on lensed fiber and polymeric diaphragm. Sens. Actuators A: Phys. 225, 25–32 (2015).
- 8. Ran, Z. et al. Novel High-Temperature Fiber-Optic Pressure Sensor Based on Etched PCF FP Interferometer Micromachined by a 157-nm Laser. IEEE Sens. J. 15, 3955–3958 (2015).
- 9. Hou, M. et al. Sensitivity-enhanced pressure sensor with hollow-core photonic crystal fiber. IEEE J. of Lightwave Technol 32, 4035–4039 (2014).
- 10. Yuan, W., Wang, F., Savenko, A., Petersen, D. H. & Bang, O. Note: Optical fiber milled by focused ion beam and its application for Fabry-Pérot refractive index sensor. *Rev. Sci. Instrum* 82, 076103 (2011).
- 11. Coelho, L. et al. Simultaneous measurement of partial pressure of O<sub>2</sub> and CO<sub>2</sub> with a hybrid interferometer. Opt. Lett. 37, 3063–3065 (2012).
- 12. Hu, G. & Chen, D. Side-hole dual-core photonic crystal fiber for hydrostatic pressure sensing. *IEEE J. of Lightwave Technol* **30**, 2382–2387 (2012).
- 13. Liu, Z., Tse, M. L. V. & Wu, C. et al. Intermodal coupling of supermodes in a twin-core photonic crystal fiber and its application as a pressure sensor. Opt. Lett. 37, 3063–3065 (2012).
- 14. Wu, C., Guan, B. O., Wang, Z. & Feng, X. Characterization of pressure response of Bragg gratings in grapefruit microstructured fibers. *IEEE J. of Lightwave Technol* 28, 1392–1397 (2010).
- 15. Xu, B., Wang, C., Wang, D. N., Liu, Y. & Li, Y. Fiber-tip gas pressure sensor based on dual capillaries. *Opt. Express* 23, 23484–23492 (2015).
- 16. Wang, Y., Wang, D. N., Wang, C. & Hu, T. Compressible fiber optic micro-Fabry-Pérot cavity with ultra-high pressure sensitivity. Opt. Express 21, 14084–14089 (2013).

# **Acknowledgements**

This work is supported by the National Natural Science Foundation of China (Grant Nos 61377094, 61661166009, 61405184).

# **Author Contributions**

D.N.W. conceives the project. W.P.C. performed the experiments. W.P.C. and D.N.W. analyzed the data and wrote the manuscript. W.P.C., D.N.W., B.X., C.L.Z. and H.F.C. discussed the manuscript.

# **Additional Information**

**Competing Interests:** The authors declare that they have no competing interests.

**Publisher's note:** Springer Nature remains neutral with regard to jurisdictional claims in published maps and institutional affiliations.

This work is licensed under a Creative Commons Attribution 4.0 International License. The images or other third party material in this article are included in the article's Creative Commons license, unless indicated otherwise in the credit line; if the material is not included under the Creative Commons license, users will need to obtain permission from the license holder to reproduce the material. To view a copy of this license, visit <a href="http://creativecommons.org/licenses/by/4.0/">http://creativecommons.org/licenses/by/4.0/</a>

© The Author(s) 2017